



BID ADDENDUM #1

CONTRACT NAME: EMERGENCY EYEWASH AND SHOWER INSTALLATION, INSPECTION, TESTING AND REPAIR SERVICES

CONTRACT NUMBER: KS021725

DATE OF ADDENDUM #1: APRIL 7, 2025

The following information shall be carefully examined, together with the Contract Documents, and all information listed in this Addendum shall be incorporated in the submission:

1. Request for Information Question and Answer Log is attached.
2. Revised Specification document is attached.

KATHLEEN SUCA
PURCHASING AGENT I,
Capital Projects and Facilities Procurement
University of Connecticut



INVITATION TO BID
REQUEST FOR INFORMATION QUESTION AND ANSWER LOG

CONTRACT NAME: Emergency Eyewash and Shower Installation, Inspection, Testing and Repair Services

CONTRACT NUMBER: KS021725

DATE: 4/3/2025

RFI NO.	QUESTION	ANSWER
1	Proposed Team Qualification List. In the bid section - Proposed Team Qualification List, the list is requested, do we need separate Resumes as well?	No, only the resume for the Contract Representative is required as stated in the Solicitation Information Sheet.
2	Portable Eyewash -Speakman. For the Speakman systems that have to be removed, cleaned, sterilized and refilled on a set schedule twice per year, should we add this cost in the fixed rate pricing or should we outline these costs in the unit pricing section?	This is to be included in the fixed, Base Price for annual service. See the revised Specification document attached. Modification the Cost Proposal Form may be considered grounds for disqualification of your bid.
3	Portable Gravity Fed Self Contained Systems. Should we add the cost of all of the Fendall pure saline Honeywell cartridge replacements for the year in the Flat rate fixed bid price or should we add a line item in the Unit pricing Section for these replacements?	This should be included in the fixed, Base Price for annual service. See Revised Specification document attached. Modification of the Cost Proposal Form may be considered grounds for disqualification of your bid.
4	Filter Changes. The Unit pricing does not mention filter changes. Should we add a line item or add filter changes costs into the flat rate pricing based on the average numbers changes per year over the last few years?	Include two changes per year in the fixed Base Price for annual service. See revised Specification document attached. Modification of the Cost Proposal Form may be considered grounds for disqualification of your bid.
5	Annual Inspections. As discussed during the prebid meeting, years ago we learned from experience to have a successful annual inspection and writeup we had to move to running the systems twice per year. Waiting for the annual led to excessive build up of dirt and bacteria in the lines leading to ruined filters and system failures. We have been running the systems twice per year for over 5 years and suggest that is the only way to clear, good successful year end test. Should we base our pricing on the current service provided today twice per year? Can we notate the Flat rate bid per occurrence or just add it up into the total fee for what is required for a successful program and year end test?	Include two (2) times per year in the fixed, Base Price for annual service. See the revised Specification document attached. Modification of the Cost Proposal Form may be considered grounds for disqualification of your bid.